## CEI WEEKLY SUMMARY OF EVENTS, OBSERVATIONS AND REMARKS

| Prepared for:  | Jackson County, FL                                  |                            |  | A                                      | IC        |  |
|--|---|----------------------------|--|--|-----------|--|
| Prepared by:   | Alday-Howell Engineering, Inc.                      |                            |  |  |           |  |
| Prepared on:   | 6/3/2025  |                            |  | Alday-Howell<br>ENGINEERING, INC.      |           |  |
| For Project:   | Indian Springs Phase 2 Water                        |                            |  |  |           |  |
|  | FDEP Grar   | nt/Loan Agreement DW320    | 381                                      | AHE # 20-034                           |           |  |
| Contractor:  | L & K Contracting, Inc.                             |                            |  |  |           |  |
| Designer:  | Alday-Howell Engineering                            |                            | Inspector: Tyler Lawrence (850) 718-7233 |  |           |  |
| Notice to Proceed:   | 10/15/2023  | Award Date:                | 9/12/2023                                | 3                                      |           |  |
| Substantial  | Completion:   | 6/29/2025                  |  | Final Completion:                      | 8/28/2025 |  |
| The report is for the w  | eek of:   | Monday, 5/27/2025          |  | thru Sunday,                           | 6/2/2025  |  |
| The contractor performed the following operations this week. Sub work is noted in parenthesis: |   |                            |  |  |           |  |
| Monday-  | Added chlorine                                      | e to disinfect water main. |  |  |           |  |
|  |   |                            |  |  |           |  |
| Tuesday-   | Flushed water main following chlorine disinfection. |                            |  |  |           |  |
|  |   |                            |  |  |           |  |
| Wednesday-   | Flushed water main following chlorine disinfection. |                            |  |  |           |  |
| Thursday-  | No work due to rain. Rain day granted.              |                            |  |  |           |  |
|  |   |                            |  |  |           |  |
| Friday-  | Flushed water main following chlorine disinfection. |                            |  |  |           |  |
| Saturday-  | No work at contractor's option.                     |                            |  |  |           |  |
| Sunday-  | No work at contractor's option.                     |                            |  |  |           |  |
| Engineer's remarks/Pending issues:   |   |                            |  |  |           |  |
| Percent Project Complete:  |   | 40%                        |  | Time Remaining (%):                    | 5%        |  |
| Invoiced to Date:  |   | \$2,433,879.21             |  | Weather days to date:                  | 22        |  |
| Original Contract Amount:  |   | \$4,492,568.00             |  | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, |           |  |
| Change Order Amount Approved:  |   | -\$550,499.25              |  | Holiday days granted:                  | 41        |  |
|  |   |                            |  | Actual Days:                           | 597       |  |
| Remaining:   |   | \$1,508,189.54             |  | Days used with deduct:                 | 534       |  |
| Days to Substantial Completion:  |   | 560                        |  | Remaining to SC:                       | 26        |  |
| Days to Final Completion:  |   | 620                        |  | Remaining to FC:                       | 86        |  |

## Rol B

Approved: Robin G. Besczezynski, Utility Project Manager (850-526-2040)

